

L.N. 400 of 2002

**THE METROLOGY ACT
ACT NO. XXV OF 2002****Hot Water Meters Regulations, 2002**

In exercise of the powers conferred by Article 19 of the Metrology Act, the Malta Standards Authority has made the following regulations:-

1. (1) The title of these regulations is the Hot Water Meters Regulations, 2002. Commencement and Citation.

(2) These regulations shall come into force on such date or dates as the Authority may by notice in the Gazette appoint and different dates may be so appointed for different purposes and different provisions of these regulations.

2. All the definitions of the Malta Standards Authority Act shall apply. In addition, for the purposes of these regulations: Definitions.
Cap. 419.

“hot water” means water the temperature of which exceeds 30 °C but does not exceed 90 °C;

“hot water meters” means meters which operate throughout in mechanical principles and as further defined in the Annex to these regulations.

3. (1) These regulations shall apply to hot-water meters intended for the continuous determination of the volume of hot water passing through them. Such meters shall be provided with a measuring device linked to an indicating device. Scope.

(2) Hot-water meters for incorporation in circulatory systems for the transfer of thermal energy are excluded from the scope of these regulations.

4. (1) Hot-water meters to which the EEC marks and signs may be affixed are described in the Annex to these regulations. They shall be subject to EEC pattern approval and shall be submitted for EEC initial verification. Meters bearing EEC marks etc.

(2) The placing on the market or entry into service of hot-water meters bearing the EEC pattern approval sign and the EEC initial verification mark, shall not be restricted refused or prohibited on the grounds of their metrological properties.

ANNEX

1. TERMINOLOGY AND DEFINITIONS

1.0. This Annex applies only to hot-water meters, hereinafter referred to as "the meter", which operate throughout on mechanical principles. Such meters either use volumetric chambers with moving boundaries or use the action of the velocity of the water on a bladed rotor (radial or axial turbine). This Annex does not apply to hot-water meters fitted with electronic devices.

1.1. Flowrate

The flowrate is the volume of water passing through the meter per unit of time.

1.2. Volume delivered

The volume delivered is the total volume of water which has passed through the meter in a given time.

1.3. Maximum flowrate ($Q_{\max}$)

The maximum flowrate, $Q_{\max}$, is the highest flowrate at which the meter must be able to function over limited periods without damage, and without exceeding the maximum permissible errors and the maximum permissible value for loss of pressure.

1.4. Nominal flowrate (Q_n)

The nominal flowrate Q_n is equal to half the maximum flowrate, $Q_{\max}$. It is expressed in cubic metres per hour and is used to designate the meter.

At the nominal flowrate, Q_n , the meter must be able to function in normal use, i.e., in continuous and intermittent operating conditions, without the maximum permissible errors being exceeded.

1.5. Minimum flowrate ($Q_{\min}$)

The minimum flowrate, $Q_{\min}$, is the flowrate above which the maximum permissible errors must not be exceeded, and is fixed as a function of Q_n .

1.6. Flowrate range

The flowrate range of the meter is bounded by the maximum and minimum flowrates, $Q_{\max}$ and $Q_{\min}$. It is divided into two regions, termed upper and lower, with different maximum permissible errors.

1.7. Transitional flowrate (Q_t)

The transitional flowrate, Q_t , is the flowrate which divides the upper and lower regions of the flowrate range and the flowrate at which the maximum permissible errors become discontinuous.

1.8. Maximum permissible error

The maximum permissible error is the limit of the error permitted by these regulations for EEC pattern approval and EEC initial verification of the meter.

1.9. Loss of pressure

Loss of pressure means the loss which is caused by the presence of the meter in the pipeline.

II. METROLOGICAL CHARACTERISTICS

2.1. Maximum permissible errors

The maximum error permitted in the lower region, from Q_{min} inclusive to Q_t non-inclusive, is $\pm 5\%$.

The maximum error permitted in the upper region from Q_t inclusive to Q_{max} inclusive, is $\pm 3\%$.

2.2. Metrological classes

Meters are divided, according to the values of Q_{min} and Q_t defined above, into the four metrological classes in the following table:

Classes	Q_n	
	$<15\text{m}^3\text{ h}$	$\geq 15\text{m}^3\text{ h}$
Class A		
Value of Q_{min}	$0.04 Q_n$	$0.08 Q_n$
Value of Q_t	$0.10 Q_n$	$0.20 Q_n$
Class B		
Value of Q_{min}	$0.02 Q_n$	$0.04 Q_n$
Value of Q_t	$0.08 Q_n$	$0.15 Q_n$
Class C		
Value of Q_{min}	$0.01 Q_n$	$0.02 Q_n$
Value of Q_t	$0.06 Q_n$	$0.10 Q_n$
Class D		
Value of Q_{min}	$0.01 Q_n$	
Value of Q_t	$0.015 Q_n$	

III. TECHNOLOGICAL CHARACTERISTICS

3.1. Construction - general provisions

The meter must be constructed in such a way as to:

- give long service and guarantee proof against fraud.
- conform with the provisions of these regulations, under normal conditions of use.

Where meters may be subjected to an accidental reversal of flow they must be capable of withstanding it without any deterioration or adverse effect on their metrological properties, and at the same time record such a reversal.

3.2. Materials

The meter must be made of materials of adequate strength and stability for the purpose for which it is to be used. It must be constructed throughout of materials which are resistant to internal and normal external corrosion and if necessary be protected by applying a suitable surface treatment. Water temperature variations within the temperature range 0 to 110 °C must not adversely affect the materials used in the construction of the meter.

3.3. Soundness - pressure tightness and temperature resistance

The meter must be able to withstand indefinitely, without malfunction, leakage, seepage through walls or permanent deformation, a continuously applied water temperature of 90 °C and the continuously applied pressure for which it is designed, termed the maximum operating pressure. The minimum value for this pressure is 10 bar.

3.4. Loss of pressure

The value of the loss of pressure is ascertained during EEC pattern approval tests; it must not exceed 0.25 bar at the nominal flowrate or 1 bar at the maximum flowrate.

On the basis of the test results, meters are classified into four groups according to whether their pressure loss at maximum flowrate does not exceed one of the following values : 1, 0.6, 0.3 and 0.1 bar. The group value must be entered on the EEC pattern approval certificate.

3.5. Indicating device

The indicating device must allow, by simple juxtaposition of its various constituent elements, a reliable, easy and unambiguous reading of the volume of water measured, expressed in cubic metres. The volume must be given either by:

- (a) the position of one or more pointers on circular scales;

(b) the display of a row of in-line consecutive digits in one or more apertures;

(c) a combination of these two systems.

The cubic metre and its multiples are indicated in black, and submultiples of a cubic metre in red.

The actual or apparent height of the digits must not be less than 4 mm.

On digital indicators (types (b) and (c)) visible displacement of all digits must be vertically upwards. The advance of a digit of any particular decade must be completed during the time that the next less significant decade changes from 9 to 0. The roller showing the least significant digits may move continuously in the case of type (c). The whole number of cubic metres must be clearly indicated.

Indicators with pointers (types (a) and (c)) must rotate in a clockwise direction. The value in cubic metres for each scale division must be expressed as 10^n where n is a positive or negative whole number or zero, thereby establishing a system of consecutive decades. Data such as the following must be shown near each part of the scale : $\times 1\,000$ - $\times 100$ - $\times 10$ - $\times 1$ - $\times 0.1$ - $\times 0.01$ - $\times 0.001$.

In both cases (dial and digital indicators):

- the unit symbol m^3 must be shown either on the dial or in the immediate vicinity of the digital indication,
- the fastest-moving and visually readable graduated element - "the control element" - must move continuously ; its scale interval is known as the verification scale interval. This control element may be permanent or may be fitted temporarily by adding detachable parts. These parts must not have any significant influence on the metrological properties of the meter.

The length of the verification scale interval must be not less than 1 mm and not more than 5 mm. The scale must consist:

- either of lines of equal thickness not exceeding one quarter of the distance between the axes of two consecutive lines and differing only in length,
- or of contrasting bands of a constant width equal to the length of the verification scale interval.

3.6. Number of figures and values of the verification scale interval

It must be possible for the indicating device to record a volume, expressed in cubic metres, corresponding to at least 1 999 hours' operation at the nominal flowrate, without returning to zero.

The size of the verification scale division must be based on the formula 1×10^n or 2×10^n or 5×10^n . During verification, it must be small enough to ensure a measurement inaccuracy of not more than 0.5 % (allowing for a possible reading error of not more than half the length of the smallest scale interval) and small enough so that at the minimum flowrate the test does not take more than 1 1/2 hours.

A supplementary device (star, disc with a reference mark, etc.) may be added in order to show the movement of the measuring device before this becomes clearly visible on the indicating device.

3.7. Adjustment device

The meter may be fitted with an adjustment device with which it is possible to alter the relationship between the volume indicated and the volume actually passed. This device is compulsory for meters which make use of the action of the velocity of the water on a bladed rotor.

3.8. Accelerating device

The use of an accelerating device for increasing the speed of the meter below $Q_{\min}$ is prohibited.

3.9. Additional devices

The meter may include a pulse-generating device provided that such a device does not appreciably affect its metrological properties.

The EEC pattern approval certificate may provide for the addition of special fixed or detachable devices to permit automatic verification of the meter.

IV. MARKS AND INSCRIPTIONS

4.1. Identification inscriptions

The meter must bear, in a legible and indelible manner, either separately or grouped together on the meter casing, on the indicator dial or on the information plate, the following items of information:

- (a) the manufacturer's name or trade name or his trademark;
- (b) the metrological class and nominal flowrate Q_n in cubic metres per hour;
- (c) the year of manufacture and the individual serial number;
- (d) one or two arrows showing the direction of flow;
- (e) the EEC pattern approval sign;
- (f) the maximum operating pressure in bar, if this can exceed 10 bar;
- (g) the maximum operating temperature in the form : 90 °C;
- (h) the letter "V" or "H" if the meter can operate properly only in the vertical (V) or horizontal (H) position.

4.2. Placing of verification marks

Space for the EEC verification marks must be provided on an essential part (normally the meter casing), which is visible without dismantling.

4.3. Sealing

The meter must be fitted with protective devices which can be sealed in such a way as to ensure, both before and after the meter has been properly installed, that neither the meter itself nor its adjusting device can be dismantled or altered without damaging the protective devices.

V. EEC PATTERN APPROVAL

5.1. Procedure

The EEC pattern approval procedure is as described in Measuring Instruments Regulations

5.2. Pattern tests

When it has been ascertained from the application file that the pattern conforms to the requirements of these regulations, the competent service must carry out laboratory tests under the following conditions:

5.2.1. Number of meters to be tested

The number of meters to be submitted by the manufacturer is as shown in the following table:

Nominal flowrate Q_n m ³ h	Number of meters
$Q_n < 1.5$	10
$1.5 \leq Q_n < 1.5$	3
$Q_n \geq 1.5$	2

Depending on how the tests progress the competent services may:

- decide not to carry out tests on all the meters submitted, or
- request additional meters from the manufacturers in order to continue tests.

5.2.2. Pressure

For the metrological tests provided for in 5.2.4 the pressure at the meter outlet must be sufficiently high to prevent cavitation.

5.2.3. Test equipment

In general, meters must be tested individually and, in all cases, in such a way as to demonstrate accurately the individual characteristics of each.

The metrological service must take all necessary steps to ensure that the relative inaccuracy in measuring the volume of water delivered does not exceed 0.3 % after allowance is made for the various causes of error in installation.

The maximum permissible inaccuracy is 5 % in the case of measurement of pressure and 2.5 % in the case of measurement of loss of pressure.

During each test, the relative variation in the flowrates must not exceed 2.5 % between $Q_{\min}$ and Q_l and 5 % between Q_l and $Q_{\max}$.

The maximum permissible inaccuracy in the measurement of temperature is 1 °C.

5.2.4. Tests

5.2.4.1. Test procedure

The tests comprise the following operations, carried out in the order shown:

1. pressure tightness test;
2. Determination of the error curves on the basis of the flowrate by ascertaining the effect of the pressure and temperature and subject to the normal installation conditions (straight sections of piping upstream and downstream of the meter, constrictions, obstacles, etc.) stipulated by the manufacturer for this type of meter;
3. Determination of pressure losses;
4. Accelerated endurance test;
5. A thermal shock resistance test for meters with a nominal flowrate Q_n of not more than 10 m³/h.

5.2.4.2. Description of tests

The tests must be carried out as follows.

- The pressure tightness test is conducted in two parts at 85 (± 5) °C:

(a) each meter must withstand without leakage, or seepage through the walls, a pressure of 1.6 times the maximum operating pressure, applied for a period of 15 minutes (see 4.1 (f));

(b) each meter must withstand without damage, or jamming, a pressure of twice the maximum operating pressure, applied for a period of one minute (see 4.1 (f)).

- The results of the error curves and loss of pressure tests must provide a sufficient number of points to enable the curves to be plotted with confidence throughout the range.

- The accelerated endurance test is carried out as set out in the table below:

Nominal flowrate of meter	Test flowrate and temperature	Type of test	Number of interruptions	Duration of pauses	Period of operation at test flowrate	Duration of start-up and rundown (sec.)
$Q_n \leq 10 \text{ m}^3/\text{h}$	Q_n and $(50 \pm 5)^\circ\text{C}$	Discontinuous	100 000	15 sec.	15 sec.	$0.15 (Q_n)^{(1)}$ minimum 1 sec.
	$Q_{\max}$ and $(85 \pm 5)^\circ\text{C}$	Continuous			100 h	
$Q_n \geq 10 \text{ m}^3/\text{h}$	Q_n and $(50 \pm 5)^\circ\text{C}$	Continuous			500 h	
	$Q_{\max}$ and $(85 \pm 5)^\circ\text{C}$	Continuous			200h	
⁽¹⁾ (Q_n) is a number equal to the value of Q_n expressed in m^3/h						

Before the first test and after each series of tests the measuring errors must be determined, under the same conditions, as a minimum requirement at the following flowrates:

$$Q_{\min} - Q_l - 0.5 Q_n - Q_{\max}$$

In each test, the volume of water passed through the meter must be sufficient to rotate the pointer or the roller on the verification scale through one or more complete revolutions and to eliminate the effects of cyclic distortion.

- The thermal shock resistance test comprises 25 cycles to be carried out as follows :

Water Temperature	Flowrate	Duration
$85 \pm 5^\circ\text{C}$	$Q_{\max}$	8min.
-	0	1 to 2 min.
Cold water	$Q_{\max}$	8min.
-	0	1 to 2 min.

5.2.5. Conditions for EEC pattern approval

A meter pattern is approved if: (a) it conforms with the administrative, technical and metrological requirements of these regulations and its Annex;

(b) tests 1, 2 and 3 under 5.2.4.1 show that it conforms to Parts II and III of this Annex as regards metrological and technological characteristics;

(c) after each accelerated endurance test and after the thermal shock resistance test, no variation in relation to the initial curve greater than 1.5 % between Q_i and Q_{max} or greater than 3 % between Q_{min} and Q_i has been observed.

5.3. EEC pattern approval certificate

The EEC pattern approval certificate may provide for the possibility of the accuracy test being carried out with cold water during initial verification.

This possibility is permitted only if, during the EEC pattern approval examination, study of the hot water/cold water rules of equivalence has enabled a cold water accuracy test to be established and has shown that a meter passing this test also complies with the maximum permissible errors laid down in 2.1.

In this case the EEC pattern approval certificate must include a description of this test and the relevant requirements, in particular those regarding the permissible errors and the test flowrates.

VI. EEC INITIAL VERIFICATION

The EEC initial verification procedure is as described in Measuring Instruments Regulations.

6.1. Verification methods

Initial verification must be carried out in a place approved by the metrological service.

The layout of the premises and the test equipment must be such that verification may be carried out in safe, reliable conditions, and with no loss of time for the person responsible for the tests. The requirements of 5.2.3 must be complied with, except with respect to temperatures where the tests are carried out with cold water in accordance with such provisions as may be laid down in the EEC pattern approval certificate. Arrangements may be made at the test centre to enable the meters to be tested in series. The exit pressure of all the meters must always be sufficient to prevent cavitation and special measures may be required to prevent interaction between meters.

The complete unit may include automatic devices, by-pass valves, flow-restrictors, etc., provided that each test circuit between the meters to be verified and the control tanks is clearly defined and that it is possible to check the internal pressure tightness of the circuits at any time.

Any type of water supply system may be used, but if several test circuits are operated in parallel, there must be no interaction incompatible with the requirements of 5.2.3.

If a control tank is divided into several chambers, the separating walls must be sufficiently rigid to ensure that the volume of a chamber does not vary by more than 0.2 % according to whether the adjacent chambers are full or empty.

6.2. Test procedure

The meters must conform to an approved pattern.

Initial verification comprises pressure tightness and accuracy tests.

6.2.1. Pressure tightness test

The pressure tightness test may be carried out with cold water. It must be carried out for one minute at 16 times the maximum operating pressure. During the test, there must be no leakage, or seepage through the walls of the meter.

6.2.2. Accuracy test

6.2.2.1. Accuracy test with hot water

The accuracy test is normally conducted with hot water at a temperature of $50 (\pm 5) ^\circ\text{C}$ at three flowrates at least:

- (a) between $0.9 Q_{\max}$ and $Q_{\max}$;
- (b) between Q_t and $1.1 Q_t$;
- (c) between $Q_{\min}$ and $1.1 Q_{\min}$.

During this test the meter must comply with the maximum permissible errors stipulated in 2.1.

If all the errors are found to lie in one direction, the meter must be adjusted so that not all the errors exceed one half of the maximum permissible error.

6.2.2.2. Accuracy test with cold water

If the EEC pattern approval certificate so provides, the accuracy test may be carried out with cold water. In this case the test is carried out in accordance with the procedures laid down in the certificate.